COP	YRIGHT by MEIKO															
1.0	machine connection: drain connection hose, DN 22 hose fitted as odour trap in interior of machine															
1.1	drain (max. 700 mm above finished floor level), DN 50															
2.0	Machine connection: fresh water supply, G 3/4"															
2.2	Soft cold water 10°C, DN 15, G 3/4 a															
	max. 0,54 mmol/l CaCO₃ (max. 3°dH)															
	Flow rate: 5 l/min Minimum flow pressure: 60 kPa / 0,6 bar in front of solenoid valve															
	Maximum pressure: 500 kPa / 5,0 bar stopcock and fine screen ≤ 25 µm															
3.0	Machine connection: electrical connection cable 5G 6mm ²															
3.1	electricity supply to the machine: 3N PE 400V ~ 50Hz															
	nominal current / - capacity: 16,3 A / 10,0 kW															
	Fuse protection: 20 A															
	Voltage equalising cable															
0.0	The master switch must be provided on site															
6.0	Heat load of warewash area The values apply for the following room conditions:															
	Room temperature 22 °C, rel. humidity 55 %															
	Recommended suction area according to German EN 16282 or any local regulations have to be observed to determine ventilation of wash areas															
	The total heat load includes 6.1															
6.1	Heat load of the machine in normal washing operation:															
	for 25 programme cycles/h total 2,7 kW, perceptible 1,8 kW, latent 0,9 kW															
	For the total space load, all other space loads must be considered. The space ventilation must be designed in accordance with EN 16282.															
all cal	bles, pipes etc leaving machine 1,8 m															
the position of the connection piping can also be mirror-inverted!																
Height adjustable: machine feet +/- 30 mm, MEIKO table feet +/- 15 mm																
_	chine Equipment															
(A) Entry height																
(D) Rinse agent pipe and suction lance																
(E) Detergent dosing unit with suction lance																
Power Wash Automatic hood system Feeding table on site																
									Disch	narge table on site						

COPYRIGHT by MEIKO











						Revision						
	M						VASH DARE		WING / BEL	Type M-ICLEAN HL M2		
	make changes resulting from technical progress. This drawing was computer generated and is not subject to the checking and any release process; it is also not subject to change				TYPE: Drawing-No S0009) .		RY	Order-No.			
					Scale 1:25	drawn: 14.08	3.2020	m-iplan	checked: 14.08.2020	m-iplan		
6	COPYR	IGHT by MEIK)			DEL						V MEIKO